

Industrial Stormwater General Permits and DEQ's NPDES Construction Stormwater General Permits; or another appropriate NPDES permit.

- ii. Stormwater discharges to underground injection control (UIC) systems.

d. Allowable Non-Stormwater Discharges

The permit does not authorize the discharge of non-stormwater from the MS4, except where such discharges satisfy one of the following conditions:

- i. The non-stormwater discharge is regulated under a separate NPDES permit.
- ii. The non-stormwater discharge originates from emergency firefighting activities.
- iii. The non-stormwater discharge is categorized as an authorized or allowable non-stormwater discharge listed in below:
 - (A) Uncontaminated water line flushing.
 - (B) Landscape irrigation. For permit registrant owned or operated areas landscape irrigation will be considered allowable only if pesticides and fertilizers are applied in accordance with manufacturer's instructions.
 - (C) Diverted stream flows.
 - (D) Uncontaminated groundwater infiltration (as defined at 40 CFR § 35.2005(20)) to separate storm sewers.
 - (E) Rising groundwaters.
 - (F) Uncontaminated pumped ground water.
 - (G) Potable water sources (including potable groundwater monitoring wells and draining and flushing of municipal potable water storage reservoirs).
 - (H) Start up flushing of groundwater wells.
 - (I) Foundation, footing and crawlspace drains (where flows are not contaminated [i.e., process materials or other pollutant]).
 - (J) Uncontaminated air conditioning or compressor condensate.
 - (K) Irrigation water.
 - (L) Springs.
 - (M) Lawn watering.
 - (N) Individual residential car washing.
 - (O) Charity car washing (provided that chemicals, soaps, detergents, steam or heated water are not used. Washing is restricted to the outside of the vehicle, no engines, transmissions or undercarriages).
 - (P) Flows from riparian habitats and wetlands.
 - (Q) Dechlorinated swimming pool discharges including hot tubs (heated water must be cooled for at least 12 hours prior to discharge).
 - (R) Fire hydrant flushing.
 - (S) Street and pavement washwaters (provided that chemicals, soaps, detergents, steam or heated water are not used).
 - (T) Routine external building wash-down (provided that chemicals, soaps, detergents, steam or heated water are not used).
 - (U) Water associated with dye testing activity.
 - (V) Discharges of treated water from investigation, removal and remedial actions selected or approved by DEQ pursuant to Oregon Revised Statute (ORS) Chapter 465.

If any of these allowable non-stormwater discharges are or becomes a significant source of pollutants, the permit registrant must prohibit that discharge or require implementation of appropriate BMPs to reduce the discharge of pollutants associated with the source before discharge to the MS4.