

ADDENDUM #1
TO
CITY OF TROUTDALE
2020 Pavement Maintenance Project

Date: May 7, 2020

To: All Planholders

CC: File

From: Nick Massey
Engineering Associate
Troutdale Public Works

The following amendments and clarifications are made to the bidding and contract documents for the City of Troutdale 2020 Pavement Maintenance Project:

1. Special Provisions, 00180.41 Project Work Schedules-
“Upon commencing work on a subject street, the Contractor shall work continuously until the respective street is completed.”
Is modified as follows:
“Upon commencing work on a subject street, the Contractor shall work continuously until the respective street is completed, with the sole exception that Contractor may perform Cold Plane Pavement Removal, 1.5” Deep up to 48 hours in advance of asphalt application. Streets must be paved and Drivable within no more than 48 hours of Cold Plane Pavement Removal.”
2. The Bid Schedule is revised to correct line item titles. Line item titles have been revised to conform to the titles defined in the 2018 Oregon Standard Specifications. The revised Bid Schedule is attached herewith. All bidders shall submit their bid on the revised Bid Schedule.
3. Pavement Line, Pavement Bar, and Pavement Legend Removal shall conform to section 00225.83 of the 2018 Oregon Standard Specifications.
4. Section 00225.83 is amended as follows:
Pavement Legend Removal shall be measured and paid on the EACH basis.
5. The City of Troutdale Standard Detail II-14 “Street Cut & Repairs” contains an inconsistency with the bid schedule and specifications. Detail II-14 incorrectly specifies to “place class “B” or “C” mix minimum”.

All references to “B or C Mix” in The City of Troutdale Standard Detail II-14 “Street Cut & Repairs” in the bidding documents, specifications, and/or drawings are replaced with “Level 2, 1/2 inch ACP”.

All overlays in this contract shall be Level 2, 3/8 inch ACP.

ADDITIONAL ADVISORY: All Planholders are reminded that the First Tier Subcontractor Disclosure Form must be submitted to the City Recorder with the bid as required by the Troutdale Municipal Code. Therefore, First Tier Subcontractor Disclosure forms are due not later than 2:00 pm on Tuesday, May 12, 2020. Failure to submit the First Tier Subcontractor Disclosure form by that time may result in the bid being found non-responsive.

BID SCHEDULE (Revised per Addendum #1)

Type or hand print legibly

Item No.	Description	Estimated Quantity	Unit of Measure	Unit Price	Total Price
1	Mobilization	1	LS		
2	Temporary Protection & Direction of Traffic	1	LS		
3	Crack Sealing	21600	LBS		
4	Slurry Sealing	60138	SY		
5	4" Asphalt Concrete Pavement Repair	1017	SY		
6	Level 2, 1/2 inch ACP	229	TN		
7	Level 2, 3/8 inch ACP	1703	TN		
8	Cold Plane Pavement Removal, 1.5" Deep	4211	SY		
9	Pavement Bar Removal	192	SF		
10	Pavement Line Removal	6477	LF		
11	Pavement Legend Removal	1	EA		

TOTAL OF BID

\$ _____